

JOB# 932569

PTS 15-150

NAME / CUST# Nutrient Control

PO# 9573-INV

PARTS

LABOR

\* \* \* \* \*

QTY	P/N	DESCRIPTION	OC	PRICE	TECH	START	STOP	HOURS
1	14	Bearing						
1	11	Seal						
1	8	Impeller			JL	10:00	12:30	2.5
1	7	Seal				1:30	3:00	1.5
2	5	Blade						
1	50	Spiral Conveyor						
1	44	O-Ring						
1	42	O-Ring						
1	38	Bearing						
1	37	O-Ring						
2	Misc			10.00				
1	SANDBLAST			25.00				
2	TO600-QT	Transformer Oil 7.64/cu		15.28				
1	Rawind			1625.00				
				1675.28				
			S.C 4.0 ✓	300.00				
			CCAL 5.5	412.50				
				2387.78				
<p>Failed hypot and surge test. Seal cavity full of water. Grinder parts very worn. Water in motor. Cord test ok. ✓</p>								