



S & S ELECTRIC MOTORS, INC.

125 FALLING SPRING ROAD
 CHAMBERSBURG, PA 17202-900
 Phone: (717)-263-1919
 Fax: (717)-263-7351

Invoice

Invoice No.:	0312378
Invoice Date:	08/15/22
Page:	1

Sold To:	Customer Number: 011294 NUTRIENT CONTROL SYSTEM 130 INDUSTRIAL DRIVE CHAMBERSBURG, PA 17201	Ship To:	Ship To Number: NUTRIENT CONTROL SYSTEM 130 INDUSTRIAL DRIVE CHAMBERSBURG, PA 17201
-----------------	---	-----------------	---

Order	Order Date	Sales Code	Ship Date	Ship Via	Terms
J935253	06/23/22	450	08/15/22		DUE NOW

Customer PO	7511-INW	PO Release		Misc Number	
--------------------	----------	-------------------	--	--------------------	--

Order	Ship	B/O	Item #	Description	Unit Price	Extension
1.0	1.0	0.0		Nameplate Data: HP:18.5 KW, MFG:CRIMAN, VOLTS:480, RPM:1740, AMPS:20.2-?, PHASE:3, MODEL:PTS18-150, SERIAL:08P00740CR		
				Special Instructions: CHECK OUT PUMP REPAIR (SUBMERSIBLE) HARDWARE,RAGS,DEGREASER,PAINT TRANSFORMER OIL		
1.0	1.0	0.0		MATERIALS	33.88	33.88
1.0	1.0	0.0		LABOR	760.00	760.00
				HYPOT & SURGE TEST-GOOD. BOLT FOR SPIRAL CONVEYOR IS ROUNDED OUT & WAS DIFFICULT TO REMOVE. DISASSAMBLE & CHECKOUT. FOUND WATER IN SEAL CAVITY, IMPELLER HAS A PIECE BROKEN OUT OF IT. REPLACE SEALS/BEARINGS/ORINGS/IMPELLER SUPPLIED BY CUSTOMER. INSTALL NEW TRANS- FORMER OIL/CLEAN/& PAINT. TEST RUN-GOOD.		

Sub Total	793.88
Discount	.00
Tax	.00
Freight	.00
Total	793.88

Paid
ACH
8/16/22
JLS

Customer