



NCS Equipment Repair Information Sheet

Customer Name Best Supply Company

Receipt/Drop Off Date \_\_\_\_\_

Model and Serial# P150-7.5 + P150-7

KW/HP \_\_\_\_\_

Site Voltage 480 Volt 3 phase

Customer Complaint \_\_\_\_\_

Service Requested Complete pump and motor rebuild

Voltage Requested 480 Volt 3 phase

Repair Shop Name \_\_\_\_\_

Repair Shop Job/Tag Number 936686

Doris Ticket Number/PO# \_\_\_\_\_

Quantity

Repair Shop Parts Request

- ① 1. 1.00520 (8) mechanical seal
- ① 2. 0.05599 (9) impeller
- ① 3. 1.00521 (12) mechanical seal
- ① 4. 1.00204 (15) bearing
- ① 5. 1.00304 (39) oring
- ① 6. 1.00300 (44) oring
- ① 7. 1.00305 (46) oring
- ① 8. 0.00244 (4) blade support
- 9.
- 10.
- 11.
- 12.
- 13.
- 14.
- 15.

To repair \$ 2139.92  
needs rewind and  
machine work.

Requesting Employee \_\_\_\_\_ Date \_\_\_\_\_